

HIMACHAL PRADESH
PUBLIC WORKS DEPARTMENT


No. PWN/CB/WA/SchoolBuilding/2022-23- 6372-73 Dated:- 06/02/2023
To

The Principal,
I.T. Next Gen School,
Makor Jamun (Suliali),
Tehsil Nurpur,
Distt. Kangra (HP).


Subject: - Regarding School Building Safety Certificate.

As intimated by the Concerned Assistant Engineer Sub Division, HP.PWD. Suliali. The school building of I.T. Next Gen School, Makor Jamun (Suliali), in Tehsil Nurpur Distt Kangra (H.P) was inspected by him along with concernd Junior Engineer on 21.01.2023. The building has neither been designed nor constructed by this department. No earthquakes resistant norms have been adopted for this building. No structure drawing approved by the competent government agency has been produced. The structure is a non Engineer structure. Hence the structure safety of this building cannot be ensured specially from earthquake point of view. The department will not be responsible for any type of loss of life and property etc, if this structure fails under any circumstances. However as per visual inspection, the building appears to be safe at present only for the year 2023-24.

DA/ Nil.


Executive Engineer,
Nurpur Division, HP.PWD.
Nurpur.

Copy to the Assistant Engineer, Sub Division, HP.PWD. Suliali for information. w.r.t. his office letter No. 5063 dated 01.02.2023.


Executive Engineer,
Nurpur Division, HP.PWD.
Nurpur.


Principal
I.T. Next Gen. School
Teh Nurpur Distt. Kangra (H.P)